

## Results for Public Schools

Fourteen public school systems have submitted results for a total of 520 schools as of July 23, 2019, with a total of 35,337 first-draw samples collected and analyzed. Of these, 571 samples collected at consumption outlets exceeded the Action Level (AL) of 20 parts per billion (ppb) of lead, and 765 samples collected at non-consumption outlets exceeded the AL of lead. There were 22 samples that exceeded the AL of lead for which a use determination could not be made.

Test Results for Public Schools Received as of July 23, 2019: 2017-2018 School Year									
County	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumption Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumption Outlets	# Elevated First Draw Samples with Unknown Use
Allegany	0								
Anne Arundel	32	3,861	1,084	2,459	318	277	50	226	1
Baltimore County	0								
Baltimore City	9	733	0	0	733	15	0	0	15
Calvert	8	480	480	0	0	1	1	0	0
Caroline	0								
Carroll	0								
Cecil	0								
Charles	0								
Dorchester	0								
Frederick	0								
Garrett	12	408	408	0	0	24	24	0	0
Harford	12	658	554	104	0	13	5	8	0
Howard	0								
Kent	0								
Montgomery	207	13,248	13,248	0	0	229	229	0	0
Prince George's	0								
Queen Anne	8	319	102	217	0	32	5	27	0
St. Mary's	12	1,597	1,451	119	27	144	67	72	5
Somerset	0								
Talbot	0								
Washington	39	3,041	829	2,211	1	120	6	114	0
Wicomico	13	498	464	34	0	25	21	4	0
Worcester	0								
<b>Total</b>	<b>352</b>	<b>24843</b>	<b>18620</b>	<b>5144</b>	<b>1079</b>	<b>880</b>	<b>408</b>	<b>451</b>	<b>21</b>

Test Results for Public Schools Received as of July 23, 2019: 2018-2019 School Year									
County	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumption Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumption Outlets	# Elevated First Draw Samples with Unknown Use
Allegany	0								
Anne Arundel	13	1390	429	907	54	41	8	32	1
Baltimore County	93	4724	2248	2470	0	264	98	166	0
Baltimore City	1	under review	under review	under review	under review	under review	under review	under review	under review
Calvert	3	181	181	0	0	0	0	0	0
Caroline	0								
Carroll	0								
Cecil	13	976	194	782	0	55	5	50	0
Charles	0								
Dorchester	2	28	28	0	0	1	1	0	0
Frederick	0								
Garrett	0								
Harford	3	468	261	207	0	67	1	66	0
Howard	40	2727	2727	0	0	50	50	0	0
Kent	0								
Montgomery	0								
Prince George's	0								
Queen Anne	0								
St. Mary's	0								
Somerset	0								
Talbot	0								
Washington									
Wicomico	0								
Worcester	0								
Total	168	10494	6068	4366	54	478	163	314	1

### Results for Nonpublic Schools

As of July 23, 2019, MDE has received test results from 169 nonpublic schools. A total of 6,651 first-draw samples have been collected and analyzed. Of these, 105 samples collected at consumption outlets exceeded the Action Level (AL) of 20 parts per billion (ppb) of lead, and 170 samples collected at non-consumption outlets exceeded the AL of lead. There were two samples that exceeded the AL of lead for which a use determination could not be made.

Test Results for Nonpublic Schools Received as of July 23, 2019 for 2017-2018 School Year									
County	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumption Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumption Outlets	# Elevated First Draw Samples with Unknown Use
Allegany	0								
Anne Arundel	5	162	66	68	28	1	0	1	0
Baltimore County	22	881	581	294	6	25	17	6	2
Baltimore City	10	650	440	210	0	19	0	19	0
Calvert	0								
Caroline	0								
Carroll	0								
Cecil	1	17	17	0	0	0	0	0	0
Charles	0								
Dorchester	0								
Frederick	4	75	46	29	0	1	1	0	0
Garrett	0								
Harford	2	21	21	0	0	0	0	0	0
Howard	3	120	31	89	0	2	0	2	0
Kent	1	7	2	5	0	0	0	0	0
Montgomery	28	1,882	563	1,285	34	39	5	34	0
Prince George's	12	347	233	114	0	15	5	10	0
Queen Anne	0								
St. Mary's	2	69	69	0	0	0	0	0	0
Somerset	0								
Talbot	3	72	35	37	0	2	2	0	0
Washington	3	60	25	35	0	2	0	2	0
Wicomico	1	2	2	0	0	1	1	0	0
Worcester	1	36	36	0	0	4	4	0	0
<b>Total</b>	<b>98</b>	<b>4401</b>	<b>2167</b>	<b>2166</b>	<b>68</b>	<b>111</b>	<b>35</b>	<b>74</b>	<b>2</b>

Test Results for Nonpublic Schools Received as of July 23, 2019 for 2018-2019 School Year									
County	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumptio n Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumptio n Outlets	# Elevated First Draw Samples with Unknown Use
Allegany	0								
Anne Arundel	3	61	28	33	0	1	0	1	0
Baltimore County	15	534	262	272	0	37	8	29	0
Baltimore City	11	356	161	195	0	4	0	4	0
Calvert	0								
Caroline	0								
Carroll	1	5	2	3	0	0	0	0	0
Cecil	1	3	3	0	0	0	0	0	0
Charles	0								
Dorchester	0								
Frederick	3	240	194	46	0	54	53	1	0
Garrett	0								
Harford	4	73	44	29	0	0	0	0	0
Howard	7	167	61	106	0	23	4	19	0
Kent	0								
Montgomery	17	610	348	244	18	38	4	34	0
Prince George's	6	67	24	43	0	1	1	0	0
Queen Anne	0								
St. Mary's	1	9	8	1	0	0	0	0	0
Somerset	0								
Talbot	0								
Washington	2	125	32	93	0	9	0	9	0
Wicomico	0								
Worcester	0								
Total	71	2250	1167	1065	18	167	70	97	0

### Results for Charter Schools

Results have been received from five charter schools as of July 23, 2019. There were no samples that exceeded the AL for lead out of 223 first-draw samples collected and analyzed. To date, no sample results have been received for the 2018-2019 school year.

Test Results for Charter Schools Received as of July 23, 2019: 2017-2018 School Year									
County*	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumption Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumption Outlets	# Elevated First Draw Samples with Unknown Use
Anne Arundel	1	50	10	34	6	0	0	0	0
Baltimore City	0								
Frederick	2	44	19	25	0	0	0	0	0
Prince George's	0								
St. Mary's	1	57	57	0	0	0	0	0	0
<b>Total</b>	<b>4</b>	<b>151</b>	<b>86</b>	<b>59</b>	<b>6</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

Test Results for Charter Schools Received as of July 23, 2019: 2018-2019 School Year									
County*	# Schools Completing Testing	# Total First Draw Samples	# First Draw Samples from Drinking Water Outlets	# First Draw Samples from Nonconsumption Outlets	# First Draw Samples with Unknown Use	# Total Elevated First Draw Samples	# Elevated First Draw Samples from Drinking Outlets	# Elevated First Draw Samples from Nonconsumption Outlets	# Elevated First Draw Samples with Unknown Use
Anne Arundel	1	72	26	45	1	0	0	0	0
<b>Total</b>	<b>1</b>	<b>72</b>	<b>26</b>	<b>45</b>	<b>1</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>

\*Only these counties have charter schools